



UOJZ.S2203 Control Units, System

Page Bottom

Control Units, System

See General Information for Control Units, System

FIKE CORP

S2203

704 S 10TH ST
PO BOX 610
BLUE SPRINGS, MO 64015 USA

Model	Type	Type Service	Type Signaling
#+	L	A, M	NC
C10-005 (b)	L	A, M, SS, WF	NC
	CS, P	A, M, WF	NC
C10-006	L	A, M, SS	NC
CyberCat 254 (c), 1016 (c), Cheetah Xi @(c)	L	A, M, SS, WF	NC
	CS (PPU)	A, M, SS, WF	DAC
	RS (PPU)	A, M, SS, WF	DAC, Rev Pol
	AUX	A, M, WF	NC
	P (PPU)	A, M, SS, WF	OT
	P (RU)	A, M, SS, WF	OT
CyberCat 50 (c), Cheetah Xi 50 @(c)	L	A, M, SS, WF	NC
	CS (PPU)	A, M, SS, WF	DAC
	RS (PPU)	A, M, SS, WF	DAC
	AUX	A, M, WF	NC
PRO (a)	CS, L, RS	A, M, SS, WF	NC
Rhino +	L	A, M, SS	NC
Shark*	AUX	A, M, WF	March, NC

L - Local System Type

A - Automatic fire alarm: Thermostats, smoke detectors, etc.

M - Manual fire alarm: Manually-operated boxes

NC - Noncoded

SS - Sprinkler Supervisory: Gate valves, water-level switches, temperature switches, carbon monoxide detectors, residential fire alarm control units, etc.

WF - Waterflow alarm: Waterflow switches

CS - Central Station System Type

P - Proprietary System Type

CS (PPU) - Central Station System Type (Protected Premises Unit)

DAC - Digital Alarm Communicator

RS (PPU) - Remote Station System Type (Protected Premises Unit)

Rev Pol - Reverse Polarity

AUX - Auxiliary System Type

P (PPU) - Proprietary System Type (Protected Premises Unit)

OT - Other Transmission Technologies

P (RU) - Proprietary System Type (Receiving Unit)

RS - Remote Station System Type

March - March Time

- Model number not included because the manufacturer is not obliged to label 100% of production.

(a) - For local system type, see footnote +. For central station or proprietary system type see footnote *.

(b) - For central station or proprietary system type see footnote *.

(c) - For local system type, see footnote +. For central station, auxiliary or remote station type see footnote *.

* - Requires additional equipment to provide indicated type service.

+ - Suitable for releasing device service.

@ - For local system types, suitable for voice evacuation using separately listed FikeGuard FGX-MP/DP.

Last Updated on 2010-07-02

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2010 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2010 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

