



FM Approvals
743A Reynolds Road
West Glocester, RI 02814 USA
T: 401 567 0590 F: 401 567 0599 www.fmglobal.com

December 9, 2002

Mr. Brad T. Stilwell
Manager, Mechanical Engineering
Fike Corporation
704 S. 10th Street
Blue Springs, MO 64015

Subject: Project Status for HFC-227ea and HFC-125 utilizing Fike DOT Cylinders

Dear Mr. Stilwell:

This letter is written to update you on the status of the FM Approval of Fike Solenoid operated hardware utilizing DOT cylinders and HFC-125 and HFC-227ea extinguishing agents.

At this time, the above mentioned Fike equipment has successfully passed all Approval tests per Standard UL 2166, and we are conducting the final review of the Design, Installation, and Maintenance Manuals for these products.

I anticipate the final Approval report will be available in the next 30 days. If you have any more questions about this project please feel free to contact me.

Sincerely,

David C. Smith
Senior Engineer / Hydraulics Group
FM Approvals / An FM Global Enterprise