

## TRIPLE COMBINATION CONTROL ACCESSORIES

### DESCRIPTION

The Manual Release Switch is a dual actuation device which provides a means of manually discharging the automatic fire extinguishing system when used in conjunction with the Fike control.

The System Abort Switch is designed to be used in conjunction with other system equipment. It provides a temporary manual means by which the agent actuation circuit may be interrupted before automatic actuation occurs.


The "Main" to "Reserve" switch is used with systems that incorporate main and reserve (back-up) agent storage. The switch may utilize 1 or 2 Form "C" contact blocks which will provide an electrical path to either the "Main" or "Reserve" release devices(s).

The Keyed Remote Reset Switch provides a method for resetting the Control Panel from a remote location.

These combination controls mount on a standard 4 gang masonry electrical box measuring 7-3/8" (187.3mm) wide x 3-3/4" (95.3mm) high x 2-3/8" (60.3mm) deep. (Fike P/N 02-2123)



**10-1649 Manual Release/System Abort/Main Reserve**



**10-1650 Manual Release/System Abort/Remote Reset**



**10-1651 Manual Release/Main Reserve/Remote Reset**



**10-1652 System Abort/Main Reserve/Remote Reset**

### APPROVALS:

- UL Listed
- FM Approved
- CSFM Approved
- BSA



*(This page is left blank intentionally)*